

TABLE 7-4: SUMMARY OF RISK REDUCTION FOR TOP RISK CIRCUIT SEGMENTS

Circuit Segment ID	Wildfire Mean Risk Score	HFTD Miles	Total Overall Risk Score(a)	Jan 1, 2023 Overall Risk(b)	Jan. 1, 2023 – Dec. 31, 2023 Mitigation Initiatives	Jan. 1, 2024 Overall Risk	Jan. 1, 2024 – Dec. 31, 2024 Mitigation Initiatives	Jan. 1, 2025 Overall Risk	Jan. 1, 2025 – Dec. 31, 2025 Mitigation Initiatives(c)	Jan. 1, 2026 Overall Risk
CLAYTON 2212681608	0.2418	33.22	124.61	43.61	EPSS Veg Mgmt. (Annual & Second Patrol) Ground Inspection Expulsion Fuse Replacement Non-Pole Backlog Pole Backlog	41.35	EPSS Veg Mgmt. (Annual & Second Patrol) Aerial Inspection Ground Inspection Expulsion Fuse Replacement Non-Pole Backlog Line Removal Pole Backlog	40.24	EPSS Veg Mgmt. (Annual & Second Patrol) Aerial Inspection Ground Inspection Tree Removal	38.21
BALCH NO 1 1101105414	0.8634	7.45	115.79	40.53	EPSS Veg Mgmt. (Annual & Second Patrol) Aerial Inspection Ground Inspection Non-Pole Backlog Pole Backlog	39.15	EPSS Veg Mgmt. (Annual & Second Patrol) Aerial Inspection Ground Inspection Pole Backlog	39.13	EPSS Veg Mgmt. (Annual & Second Patrol) Aerial Inspection Ground Inspection	39.13
CLOVERDALE 1102672	0.2415	22.45	102.89	36.01	EPSS Veg Mgmt. (Annual & Second Patrol) Ground Inspection Expulsion Fuse Replacement Non-Pole Backlog Pole Backlog	34.86	EPSS Veg Mgmt. (Annual & Second Patrol) Aerial Inspection Expulsion Fuse Replacement Non-Pole Backlog Pole Backlog	34.32	EPSS Veg Mgmt. (Annual & Second Patrol) Non-Pole Backlog Pole Backlog	34.29
PLACERVILLE 21067522	0.0696	73.53	89.56	31.35	EPSS Veg Mgmt. (Annual & Second Patrol) Undergrounding Expulsion Fuse Replacement Non-Pole Backlog Tree Removal Pole Backlog	29.14	EPSS Veg Mgmt. (Annual & Second Patrol) Ground Inspection Expulsion Fuse Replacement Non-Pole Backlog Line Removal Pole Backlog	28.09	EPSS Veg Mgmt. (Annual & Second Patrol) Aerial Inspection Ground Inspection Non-Pole Backlog Pole Backlog	28.09
MIDDLETOWN 1101644756	0.2412	15.26	84.43	29.55	EPSS Veg Mgmt. (Annual & Second Patrol) Expulsion Fuse Replacement Non-Pole Backlog Tree Removal Pole Backlog	25.70	EPSS Veg Mgmt. (Annual & Second Patrol) Ground Inspection Expulsion Fuse Replacement Non-Pole Backlog Tree Removal Pole Backlog	23.25	EPSS Veg Mgmt. (Annual & Second Patrol) Aerial Inspection	23.25
STANISLAUS 1701CB	0.1181	38.52	82.71	28.95	EPSS Veg Mgmt. (Annual & Second Patrol) Undergrounding Overhead Hardening Expulsion Fuse Replacement Non-Pole Backlog Pole Backlog	23.17	EPSS Veg Mgmt. (Annual & Second Patrol) Non-Pole Backlog Tree Removal Pole Backlog	22.09	EPSS Veg Mgmt. (Annual & Second Patrol) Ground Inspection Expulsion Fuse Replacement Non-Pole Backlog Pole Backlog	21.96
PLACERVILLE 210611132	0.0987	44.47	80.24	28.09	EPSS Veg Mgmt. (Annual & Second Patrol) Ground Inspection Expulsion Fuse Replacement Non-Pole Backlog Pole Backlog	27.20	EPSS Veg Mgmt. (Annual & Second Patrol) Expulsion Fuse Replacement Non-Pole Backlog Line Removal Pole Backlog	26.58	EPSS Veg Mgmt. (Annual & Second Patrol) Ground Inspection Undergrounding Overhead Hardening Pole Backlog	25.44
CALAVERAS CEMENT 1101544800	0.1772	23.54	78.10	27.33	EPSS Veg Mgmt. (Annual & Second Patrol) Expulsion Fuse Replacement Non-Pole Backlog Pole Backlog	26.78	EPSS Veg Mgmt. (Annual & Second Patrol) Ground Inspection Expulsion Fuse Replacement Non-Pole Backlog Pole Backlog	25.11	EPSS Veg Mgmt. (Annual & Second Patrol) Aerial Inspection Ground Inspection Expulsion Fuse Replacement	24.89
ALLEGHANY 1102CB	0.2280	18.79	77.26	27.04	EPSS Veg Mgmt. (Annual & Second Patrol) Surge Arrestor Replacement Aerial Inspection Ground Inspection Non-Pole Backlog Pole Backlog	26.13	EPSS Veg Mgmt. (Annual & Second Patrol) Aerial Inspection Ground Inspection Expulsion Fuse Replacement Non-Pole Backlog Line Removal Pole Backlog	25.53	EPSS Veg Mgmt. (Annual & Second Patrol) Aerial Inspection Ground Inspection Undergrounding Pole Backlog	< 0.1
MARIPOSA 210237282	0.0673	53.25	75.96	26.59	EPSS Veg Mgmt. (Annual & Second Patrol) Expulsion Fuse Replacement Non-Pole Backlog Tree Removal Pole Backlog	25.70	EPSS Veg Mgmt. (Annual & Second Patrol) Expulsion Fuse Replacement Non-Pole Backlog Tree Removal Line Removal Pole Backlog	23.29	EPSS Veg Mgmt. (Annual & Second Patrol) Non-Pole Backlog Pole Backlog	23.29
WEST POINT 11024788	0.0532	74.27	73.38	25.68	Veg Mgmt. (Annual & Second Patrol) Expulsion Fuse Replacement Non-Pole Backlog Tree Removal Line Removal Pole Backlog	23.16	Veg Mgmt. (Annual & Second Patrol) Expulsion Fuse Replacement Non-Pole Backlog Line Removal Pole Backlog	22.60	Veg Mgmt. (Annual & Second Patrol) Expulsion Fuse Replacement Pole Backlog	22.45
CALPINE 1144CB	0.1428	26.76	72.66	25.43	EPSS Veg Mgmt. (Annual & Second Patrol) Ground Inspection	25.42	EPSS Veg Mgmt. (Annual & Second Patrol) Aerial Inspection Ground Inspection Expulsion Fuse Replacement	25.40	EPSS Veg Mgmt. (Annual & Second Patrol) Aerial Inspection	25.40
EL DORADO PH 210119752	0.0945	41.58	69.49	24.33	EPSS Veg Mgmt. (Annual & Second Patrol) Ground Inspection Undergrounding Overhead Hardening Non-Pole Backlog Tree Removal Pole Backlog	21.34	EPSS Veg Mgmt. (Annual & Second Patrol) Aerial Inspection Expulsion Fuse Replacement Non-Pole Backlog Pole Backlog	21.04	EPSS Veg Mgmt. (Annual & Second Patrol) Ground Inspection Expulsion Fuse Replacement Non-Pole Backlog Pole Backlog	20.75

COLUMBIA HILL 1101CB	0.0757	47.94	65.82	23.04	EPSS Veg Mgmt. (Annual & Second Patrol) Ground Inspection Expulsion Fuse Replacement Non-Pole Backlog Tree Removal Pole Backlog	21.70	EPSS Veg Mgmt. (Annual & Second Patrol) Aerial Inspection Ground Inspection Expulsion Fuse Replacement Non-Pole Backlog Pole Backlog	21.36	EPSS Veg Mgmt. (Annual & Second Patrol) Aerial Inspection Pole Backlog	21.36
-------------------------	--------	-------	-------	-------	---	-------	--	-------	---	-------

Note: Circuit segments are selected from highest to lowest mean wildfire or ignition risk and sorted by total overall utility risk. Based on that ranking, PG&E identifies 14 circuit segments that fall within the top 5 percent of risk.

- (a) Excludes the risk reduction associated with EPSS.
- (b) Accounts for risk reduction associated with EPSS.
- (c) Projected 2026 underground miles are listed for awareness only. They are not factored into the Jan. 1, 2026 Overall Risk value as risk reduction benefits do not occur until Jan. 1, 2027.